

FAN COIL UNIT

(FOUR WAY CASSETTE)



TRUST AIR CONDITIONING EQUIPMENT CO.
Prepared By: Engineering & R & D Department.

Troubleshooting

No.	Malfunction	Operation lamp	Timer lamp	Defrosting lamp	Alarm lamp	Error code
1	Room temp. sensor checking channel is abnormal	X	☆	X	X	E2
2	Evaporator pipe temp. sensor checking channel is abnormal	☆	X	X	X	E3
3	EEPROM malfunction	☆	☆	X	X	E7
4	Water-level switch malfunction	X	X	X	☆	E8



Air Conditioning Systems

Cooling & Heating

TRUST AIR-CONDITIONING EQUIPMENT CO.

Shiraz office: 8 th floor, Alvand Blog., Dostan St.,
Moaliabad Ave., SHIRAZ, IRAN., Post code: 71877-14446

Tel.: +98-71-36341070

Fax.: +98-71-36341094

Tehran office: No. 19- koohe nour St.- Motahhari St.-

TEHRAN, IRAN., Post code: 15876-73111

Tel.: +98-21-89389

Fax.: +98-21-88541903

Ahwaz office: No. 309- Kaveh St.- AHWAZ, IRAN., Post code: 61939-47911

Tel.: +98-61-32230647-8

Fax.: +98-61-32230647

E-mail: info@trustacs.com

Web site: <http://www.trustacs.com>

پرتو پرتو در اولین جشنواره بین المللی
برترین نام و نشان های تجاری ایران

